

~~SECRET~~

00190050-2

10 JAN 1974

Mr. J. Wayne Roy
Acting Director
Space Management Division
Office of Operating Program
Public Buildings Service
General Services Administration
Washington, D. C. 20407

Dear Mr. Roy:

Please refer to a letter dated 17 April 1973 from Mr. James W. McMahon, Acting Chief, Metro Operations, Space Management Division, General Services Administration, concerning deficiencies in the HVAC system of 1000 North Glebe Road, Arlington, Virginia.

25X1C4a

25X1C4a

25X1C4a

A recent survey of the HVAC system reveals that most of the deficiencies have been corrected and the systems are operating satisfactorily. It was discovered, however, that some of the air filters in the air handlers are improperly installed. It is requested that the Lessor be notified so that corrective action can be taken.

Sincerely,

25X1A9a

Acting Chief
Real Estate and Construction Division, OL

Distribution:

- Orig - Addressee
- 1 - OL/RECD Official
- 1 - OL/RECD/REB Chrono
- 1 - OL/RECD/R&FU
- 1 - OL/RECD/HEB
- ① - Daily
- 1 - OL Reader

25X1A8a

25X1A9a OL/RECD/REB/ :cmt/3438 (9 Jan 74)

WARNING NOTICE
SENSITIVE INTELLIGENCE SOURCES
AND METHODS

~~SECRET~~

CLASSIFIED BY
EXEMPT FROM GENERAL DECLASSIFICATION
SCHEDULE OF E.O. 11652, EXEMPTION CATEGORY:
§ 5B(1), (2), (3) or (4) (circle one or more)
AUTOMATICALLY DECLASSIFIED ON
(unless impossible, insert date or event)

FOIAb3a

TRANSMITTAL SLIP		
<div style="background-color: black; height: 20px; width: 100%;"></div>		
ROOM NO.	BUILDING	
1116	Key	
REMARKS:		
FROM:		
04/RECO		
ROOM NO.	BUILDING	EXTENSION
906	Ames	
FORM NO. 241 1 FEB 55		
REPLACES FORM 36-8 WHICH MAY BE USED.		
(47)		